

Report Date..... 2-Jul-09  
EML Project ID..... 090622-PWO  
Your ID..... Polylok 525  
Effluent filter

POLYLOK TEST FACILITY  
3 Fairfield Blvd  
Wallingford, CT 06492

Date Sampled..... 22-Jun-09  
Date Submitted..... 22-Jun-09

Attn: Mr. Peter Gavin

Values in mg/L unless otherwise noted.  
ND = Not Detected. NR = Not Required

Amended Report

Parameter	#525 Before	#525 After
Biochemical Oxygen Demand	944.5	355.2
Total Suspended Solids	840.	53.0

\_\_\_\_\_  
 Technical Reviewer: [Signature] Title: [Signature] TAB:BLK  
 Transcript Reviewer: [Signature] Title: [Signature]

